

Auditing Test Report

Date: 05/07/2018

Lab No.: 40329-6

Jab No.: SA13-4043

Client

Sampling Date:

Saudi Vitrified Clay Pipe Co.

03/07/2018

P.O. Box 6415

Testing Date:

Riyadh 11442

04/07/2018

Kingdom of Saudi Arabia

Auditing Purpose:

Testing of Vitrified Clay Pipes jointed by system C according to EN 295-1:2013

Size Description:

Nominal Size:

DN 200 SS * 1750 mm

Jointing System:

System C

Class:

160

Description of Sampling

Samples were collected randomly from the stock at the client's manufacturing works in Riyadh (Kingdom of Saudi Arabia) by the agent of the Suhaimi - Fugro

Underlying specification /description of the tests

EN 295-1:2013

"Vitrified clay pipe systems for drains and sewers - Part 1: Requirements for pipes, fittings & joints"

GSO EN 295-1:2008

"Vitrified clay pipe systems for drains and sewers - Part 1: Requirements for pipes, fittings & joints"

EN 295-2:2013

"Vitrified clay pipe systems for drains and sewers - Part 2: Evaluation of conformity and sampling"

EN 295-3:2012

"Vitrified clay pipe systems for drains and sewers - Part 3: Test Methods





Test Results

Pipes	Test Type		Unit	Sample 1	Sample 2	Sample 3	Req.	Result
	Marking (visual Inspection)		_	✓	✓	✓	✓	~
	Crushing Strength		KN/m	58	63	61	≥ 45	~
	Internal Barrel Diameter "D1"		mm	198	201	200	≥ 195	~
	Length		mm	1760	1760	1750	1750 +4% -1%	~
	Water Tightness		L/m²	0.021	0.018	0.02	≤ 0.04	~
	Deviation from Straightness		mm	2.5	3.1	3.5	< 4.0	~
	Squareness of Ends	Socket	mm	2.5	2.8	2.7	< 6.0	
		Spigot	mm	3.8	3.5	3.4		~
	Airtightness		mm	10	6	12	Drops ≤ 25	~
	Water Absorption		%	2.9	3.5	3.4	≤6%	~
	Bending Moment Resistance		KNm	9.6	9.2	9.8	≥ 6.2	/
Joint Assembly	Joint Interchangeability		mm	260.3	260.1	259.9	260 ± 0.5	V .
	Watertightness under Angular Deflection		-	No leak, Deflection applied is 80 mm/m for 5 min.			No visible leakage	~
	Watertightness under Shear			No leak, Shear force applied is 5.0 KN for 15 min.			No visible leakage	~
	Continuity of Invert		mm	2.5	1.7	2.1	≤ 4	~

FUGRO - SUHAIMI LTD (Riyadh Lab. 01)ANIL K MATHEW C. R. 2050004110

(Stamp Valic only for Lab Tast Reports: ختم صالح فقط لتقارير المختبر