

Auditing Test Report

Date:

10/01/2024

Test Report No.: SA13-4043/34

Client

Sampling Date:

06/01/2024

Saudi Vitrified Clay Pipe Co.

P.O. Box 6415

Test Date:

07/01/2024

Riyadh 11442

Kingdom of Saudi Arabia

Auditing Purpose:

Testing of Vitrified Clay Pipes jointed by system C according to EN 295-1:2013

Size Description:

Nominal Size:

DN 500 * 2000 mm

Jointing System:

System C

Class:

120 - Class B

Description of Sampling

Samples were collected randomly from the stock at the client's manufacturing works in Riyadh (Kingdom of Saudi Arabia) by the agent of the Suhaimi - Fugro

Underlying specification /description of the tests

EN 295-1:2013

"Vitrified clay pipe systems for drains and sewers - Part 1: Requirements for pipes, fittings & joints"

GSO EN 295-1:2008

"Vitrified clay pipe systems for drains and sewers - Part 1: Requirements for pipes, fittings & joints"

EN 295-2:2013

"Vitrified clay pipe systems for drains and sewers - Part 2: Evaluation of conformity and sampling"

EN 295-3:2012

"Vitrified clay pipe systems for drains and sewers - Part 3: Test Methods





Test Results of DN 500 SS - Class B

Test Report No.: SA13-4043/34

	Test Ty	pe	Unit	Sample 1	Sample 2	Sample 3	Req.	Result
	Marking (visual Inspection)		-	✓	~	✓	~	1
	Crushing Strength		KN/m	82	85	77	≥ 65	/
	Internal Barrel Diameter "D1"		mm	502	502	505	≥ 487	/
	Length		mm	2005	2005	2010	2000 +4% -1%	/
Pipes	Water Tightness		L/m²	0.02	0.03	0.03	≤ 0.04	~
ä.	Deviation from Straightness		mm	0.4	0.6	0.4	< 3.0	1
	Squareness of Ends	Socket	mm	4.1	4.3	3.6	< 10.0	/
		Spigot	mm	3.5	4.2	4.5		
	Airtightness		mm	15	18	20	Drops ≤ 25	1
	Chemical Resistance		%	0.13	p r 0.12	0.11	0.10-0.25%	1
	Water Absorption		%	4.2	4.1	3.9	≤6%	00 / S
2	Joint Interchangeability (D4)		mm 7	605.3	605.3	605.4	605 ± 0.5	/
Joint Assembly	Watertightness under Angular Deflection		0.5 bar	No leak, Deflection applied is 30 mm/m for 5 min.			No visible leakage	/
int As	Watertightness under Shear		0.5 bar	No leak, Shear force applied is 12.5 KN for 15 min.			No visible leakage	1
٩	Continuity of Invert		mm	3.4	3.4	3.6	≤ 5.0	~

FUGRO - SUHAIMI LTD

Mohammad Afaq

