

TABLE 37

Guideline for the Type of Bedding Construction

(Please see Reference 1 pages 30 & 31 attached)

For SVCP calculated bedding factors of different pipe diameters, please see corresponding attached tables and refer to this guideline for the type of bedding construction to be used.

Bedding Factor (B.F.) values	Type of Bedding Construction
$1.1 < \text{B.F.} \leq 1.9$	Class F (Granular Bedding)
$1.9 < \text{B.F.} \leq 2.5$	Class B or S (Granular Bedding)
$2.5 < \text{B.F.} \leq 2.6$	Class A, Plain Concrete Cradle
$2.6 < \text{B.F.} \leq 4.5$	Class A, Plain Concrete Surround

Note: The beddings of pipelines with 1.0m or less of cover require precautions to be taken besides those needed to resist the loads acting upon them