

5.4 -Approval Certificates in Bahrain

Project..... MADINAT HAMAD : DI-NBH 4 المشروع
 Contract..... SITE 51/SOUTH SWEET المقابلة
 From (Contractor)..... MOHAMMAD HASI ALI GROUP من المقاول
 Signed (By Contractor)..... [Signature] توقيع المقاول
 Date Submitted..... 06-08-92 تاريخ الاستلام

مندوب المهندس

**MATERIAL APPROVAL
 CERTIFICATE**

No. 24/92 الرقم

We request approval to the following material for use on the above contract.

1. Material & Location	VITRIFIED CLAY PIPE & FITTINGS (SS & ES)	١ . المادة المستعملة
2. Manufacturer	SAUDI VITRIFIED CLAY PIPE CO. LTD.	٢ . اسم المنتج
3. Description	FOR MAIN SEWER LINES & LATERALS	٣ . الوصف
4. Local Supplier	ZAYANI ENTERPRISES	٤ . الوكيل في البحرين
5. MOH. Specn. Clause	G-1	٥ . مواصفات وزارة الاسكان
6. Standard Requirement	150MM, 200MM, 300MM DIA. CLAY PIPES TO BS 65 & DIN 1230, FITTINGS TO BS 539	٦ . المطلوب القياسي
7. Estimated Delivery Period	2 TO 3 WEEKS	٧ . الفترة التقديرية للإيصال
8. Estimated date reqd. at site	ONE WEEK	٨ . التاريخ المطلوب للإيصال
9. Enclosures: Samples/ Cat/Test Results	CATALOGUES, SAMPLE AT SITE	٩ . المرفقات : عينات ، كتلوجات نتائج ، اختبارات

Comments:

ملاحظات :

It is recommended to approve/
 reject this material

نوصى بالموافقة / عدم الموافقة على
 هذه المادة

Signature

Date

التوقيع :

التاريخ :

Approved/Rejected:

مقبول / غير مقبول

(by Head of Construction Supervision/Senior Materials Engineer

رئيس الانشاءات / مهندس
 مواد أول

ملاحظة ١ - هذه الموافقة خاصة بمادة معينة وليس بمادة شبيهة .

NOTE 1 — This approval relates only to identical materials, not similar materials.

ملاحظة ٢ - المواد التي لم يوافق عليها تعتبر مواداً مرفوضة .

NOTE 2 — Materials which have not been approved are deemed to have been rejected.

ملاحظة ٣ - الموافقة على المنتجات أو المواد لا يعفى المقاول بأي حال من الأحوال عن مسؤوليته الكاملة حسب العقد

NOTE 3. Approval of products or materials does not in any way relieve the
 Contractor of his full responsibilities under the contract.

COPIES: White — Contractor, Pink — S.S.E, Blue — Green.

النسخ : البيضاء : المقاول ، الوردية : استشاري الموقع

الزرقاء : رئيس الانشاءات ، الخضراء : مهندس مواد أول



W80/L.06.01/1800/GLM/87

1 October 1987

Fakhro Commercial Services,
P.O.Box 2200,
Manama,
Bahrain.

Dear Sirs,

SAUDI VITRIFIED CLAY PIPE CO.

Further to the recent conversation between Mr. Fakhro and the Assistant Under Secretary for Public Works Affairs, I would like to confirm the following points.

- 1) Pipes in the diameter range 150mm - 400mm have been approved for use on the following Ministry of Works, Power & Water contract.

Name of Contract : Diplomatic Area 107A
Name of Consultant: Watson Hawksley

- 2) This approval relates to the above contract only and approval for use on any other contract must be obtained by the Contractor from the SO/RE.
- 3) Any approval is subject to checks on product quality on site deliveries.

I trust that the above is of assistance to you.

Yours faithfully,

G.L. Macmillan
Manager, Materials Testing
& Research Department
(Cir.) (110) (211-55)

W: M/S. Zayan. Enterprises

Attn: Mr. Mohd. Jamal

POA 910599



PUBLIC WORKS AFFAIRS
ROADS AND SEWERAGE DIRECTORATE
S.D.E.S. DEPARTMENT

Supervising Officer : PWA.

Project Title : STORM WATER AND SEWERAGE SCHEME

AT MINA SALMAN INDUSTRIAL AREA-

Project No. :

Contract No. : A5-B/92

Contractor : BARRAIN MOTOR CO. WLL

No. : 046/MAR/92

MATERIAL APPROVAL CERTIFICATE

(This Form is not to be used for changes to the specifications)

We request approval to the following material for use on the above contract.

1. Material	CLAYWARE PIPES - 150mm end 200mm
2. Manufacturer	SAUDI VITRIFIED CLAY PIPES CO. LTD P.O. Box 6415, RIVADH 11442, SAUDI ARABIA
3. Description & Location of use	FOR SEWER LINES.
4. Local Supplier	ZAYANI ENTERPRISES-
5. R&SD Specn. Clause Gen. Part.	SEWERAGE AND DRAINAGE SPECIFICATIONS PL. (D) 17.2.
6. Technical Details	BS. 65
7. Estimated Delivery Period	TWO WEEKS.
8. Estimated date reqd. at site	IMMEDIATELY.
9. Enclosures : Samples/Cat/Test Results	CATALOGUE ATTACHED

Meets does not Meet Requirements

REMARKS To comply with P.M. Edict 2!
for materials and PWA spec etc.

For Signature: [Signature] SITE SUPERVISOR

Date: 13/4/92

For CONTRACTOR Signature: [Signature]

Date: 28/3/92

Approved/Rejected: [Signature] CONST. SUPERVISION ENGINEER

NOTE 1 - This approval Relates only to identical materials, not similar materials.
NOTE 2 - Materials which have not been approved are deemed to have been rejected.
COPIES : White - Contractor; Pink - Jol. Supervisor; Blue - Const. Supervision Eng.
Yellow - Retained by Contractor for Monitoring

ARAD BAY INFRASTRUCTURE PHASE - 1 CONTRACT NO: SP-2-2001

CONTRACTOR:
HABIB ALI AWACHI & SONS CONT. CO.W.L.L.

CONSULTANTS:
GIBB/MSCEB

MATERIAL APPROVAL NO. 10 'C'

DATE: 26-07-01

MATERIAL NAME: VITRIFIED CLAY PIPES

MANUFACTURER: H/5 Sumeil Vitrified Clay Pipe Co.

ORIGINATED FROM: SAUDI ARABIA

LOCAL SUPPLIER: H/5 GFC CONTRACTORIAL SERVICES

LOCATION OF USE: SEWERAGE WORKS

SAMPLE (If any): AT SITE

TEST RESULTS: ATTACHED

REQUESTED APPROVAL DATE:

EXPECTED DATE OF ARRIVAL:

DATE REQUIRED AT SITE:

TEL NO. 96611776811

TEL NO.

TEL NO. 727100


DRAWING NO. FW 0224
c14

We request your approval to the following for use on the above project and location which is as per the requirement specified in the contract.

Spec. Clause/Page No.	Specified Requirements	Contractor's Proposals
12.12.2		
12.8		

ACCOMPANYING ENCLOSURES: TEST RESULTS, SAMPLE

FOR CONTRACTOR:


SIGNATURE:  **NAME:** H/11/10 **DESIGNATION:** Sr. Project Coord. **DATE:** 26-7-01

CONSULTANTS:


NOTE: THIS APPROVAL DOES NOT RELIEVE THE CONTRACTOR OF HIS CONTRACTUAL OBLIGATIONS.

DATE RECEIVED: 26-07-2001 APPROVED: ~~FOR GIBB~~

REMARKS: NOTE
PLEASE FABRICATE JOINTS 2 - 316"
AS DISCUSSED WITH OUR MR SUMAIL
KALADKAL.

FOR GIBB 

DATE: 4-Aug-2001

FOR CAA		
COMMENTS		
No Comments		
	A. F.	DATE
SIGNATURE	NAME	DESIG & SEAL
DATE: 09/11/2001		

APPRO: MR. MAHMOUD ABU SEBBA




in association with

ايس - المؤيد
ACE-ALMOAYED
CONSULTING ENGINEERS

Ref: MO/01/NPH-IC/1532/KS/ay

6th November 2001

A.A. NASS Contracting Co.
P.O. Box 669
Manama, Bahrain



Attention: Mr. Brett Cooper - Project Manager

Dear Sir,


Re: Khalifa Bin Salman Port & Industrial Area at Hidd
Industrial Area Infrastructure Contract-Reduced Scope
Vitrified Clay Pipes

Further to our letter ref. MO/01/NPH/1231/KS/ay dated 15th August 2001. In view of the test certificates from the approved independent testing laboratory ; M/s Fugro-Suhaimi received vide your letter ref. CD/PSM/L/1237/01 dated 7th October 2001, please be advised that the Vitrified Clay Pipes produced by SVCP Co. of K.S.A. are hereby approved.

Yours faithfully,
For Posford Duvivier/ACE-Almoayed

K. Sefri
Project Manager

cc: CPD
C. Crossan



Recd

06/11/01

P.O. Box 844
Manama, Bahrain

Tel: 223 250 / 227 912 Fax: 227 900

4 Dean's Yard, Westminster
London SW1P 3NL, U.K.

Tel: (0)171 2222115 Fax: (0)171 2222659



Supervising Officer: S.D.P.
 Project Title: Town Contract for Sewerage & Drainage works 1977
 Project No.: Various
 Contract No.: 45-67/97
 Contractor: AL-DOOR

PUBLIC WORKS AFFAIRS
ROADS AND SEWERAGE DIRECTORATE
S.D.E.S. DEPARTMENT
 No.: 8

MATERIAL APPROVAL CERTIFICATE

(This Form is not to be used for changes to the specifications)

We request approval to the following material for use on the above contract.

1. Material	CW. pipes. G.C.C product.
2. Manufacturer	Saudi vitrified clay pipe Co. Ltd Saudi Arabia
3. Description & Location of use	Main Line
4. Local Supplier	(B.F.G.C.)
5. R&SD Specn. Clause Gen Part.	
6. Technical Details	as per Catalog
7. Estimated Delivery Period	Ex stock.
8. Estimated date reqd. at site	As Required.
9. Enclosures: Samples/Cat/Test Results	

Meets/~~does not~~ Meet Requirements

REMARKS N/A Subject to site physical checks.

For [Signature] SITE SUPERVISOR

Date: 20/10/97

For CONTRACTOR [Signature] Signature

Date: 8-10-97

Approved/Rejected [Signature] CONST. SUPERVISION ENGINEER

NOTE 1 — This approval Relates only to identical materials, not similar materials.
 NOTE 2 — Materials which have not been approved are deemed to have been rejected.
 COPIES: White — Contractor; Pink — Job Supervisor; Blue — Const. Supervision Eng.
 Yellow — Retained by Contractor for Monitoring

ATTN: MR MAHMOOD
 FROM — MOHAMMAD JABAL
 BAHIG

17.5.98
 FACSIMILE MESSAGE



Supervising Officer: AZIZ ZAINAL
 Project Title: Sewerage and Drainage Scheme
Salmaniya 309
 Project No.: 42060
 Contract No.: 45-115/97
 Contractor: ALAMIN CONTRACTOR

**PUBLIC WORKS AFFAIRS
 ROADS AND SEWERAGE DIRECTORATE
 S.D.E.S. DEPARTMENT**

No.: 8

MATERIAL APPROVAL CERTIFICATE

(This Form is not to be used for changes to the specifications)

We request approval to the following material for use on the above contract.

1. Material	CW Pipes C.e.e Product
2. Manufacturer	Saudi Intrifund Clay pipe Co. Ltd Saudi Arabia
3. Description & Location of use	Main Line
4. Local Supplier	(B.F.C.E)
5. R&SD Spec. Clause Gen. Part.	
6. Technical Details	As per catalog
7. Estimated Delivery Period	Ex stock
8. Estimated date reqd. at site	As required
9. Enclosures: Samples/Cat/Test Results	

Meets/~~does not Meet~~ Requirements

REMARKS Must be glazed internally and externally

For Signature SOP
[Signature] SITE SUPERVISOR
 Date: 16/5/98

For CONTRACTOR Signature [Signature]
 Date: 03.5.98

Approved/~~Rejected~~ _____
 CONST. SUPERVISION ENGINEER

NOTE 1 — This approval Relates only to identical materials, not similar materials.

NOTE 2 — Materials which have not been approved are deemed to have been rejected.

COPIES: White — Contractor; Pink — Job Supervisor; Blue — Const. Supervision Eng.
 Yellow — Retained by Contractor for Monitoring

TO: MR MAHMOOD
 FROM: MUHAMMAD SAMI



Supervising Officer: SOP/JJAZ A RAMA
 Project Title: Septic tanks drainage scheme
 Project No.: 46083
 Contract No.: 45-97/97
 Contractor: Anals transport

PUBLIC WORKS AFFAIRS
 ROADS AND SEWERAGE DIRECTORATE
 S.D.E.S. DEPARTMENT

No.: 3

MATERIAL APPROVAL CERTIFICATE

(This Form is not to be used for changes to the specifications)

We request approval to the following material for use on the above contract.

1. Material	<u>2000/50MM Ø w/c pipe (DOUBLE GLOUED) AND FITTINGS</u>
2. Manufacturer	<u>SAUDI VITRIFIED CLAY PIPE</u>
3. Description & Location of use	<u>PIPE LAYING</u>
4. Local Supplier	<u>BATHIAN FIBRE CLAY FACTORY</u>
5. R&SD Specn. Clause Gen. Part.	<u>AS PER MANUFACTURER DETAILS</u>
6. Technical Details	<u>AS PER BS STANDARD</u>
7. Estimated Delivery Period	<u>3 WEEKS</u>
8. Estimated date reqd. at site	<u>3 WEEKS</u>
9. Enclosures: Samples/Cat/Test Results	<u>Test Results</u>

Meets/does not meet Requirements

REMARKS No. Subject to site physical checks

For Signature [Signature] SITE SUPERVISOR

For CONTRACTOR Signature [Signature]

Date: 23/12/1998

Date: _____

Approved/Rejected [Signature]
 CONST. SUPERVISION ENGINEER

NOTE 1 — This approval Relates only to identical materials, not similar materials.
 NOTE 2 — Materials which have not been approved are deemed to have been rejected.
 COPIES: White — Contractor; Pink — Job Supervisor; Blue — Const. Supervision Eng.
 Yellow — Retained by Contractor for Monitoring

Supervising Officer : MR. JIM MURPHY

Project Title : BAHRAIN SEWERAGE PROJECT CONTRACT 74-5

NORTH SANABIS TRUNK SEWER (PHASE 1)

Contract No. : 74-5/1

Contractor : M/S.ROBODH CONTRACTING EST.,

No. : M-21



**PUBLIC WORKS AFFAIRS
ROADS AND SEWERAGE DIRECTORATE**

MATERIAL APPROVAL CERTIFICATE

(This Form is not to be used for changes to the specifications)

We request approval to the following material for use on the above contract.

1. Material	VITRIFIED CLAY PIPES & FITTINGS. DIA METERS 300MM DIA & 250 MM DIA.
2. Manufacturer	M/S.SAUDI VITRIFIED CLAY PIPES CO LTD
3. Description & Location of use	AS SEWER PIPES FOR SECONDARY SEWERS WHERE EVER SPECIFIED
4. Local Supplier	M/S.ZAYANI ENTERPRISES
5. R&SD Specn. Clause Gen. Part.	SECTION 'D' , CLAUSE D1.7.2, PAGES D-4 & D-5
6. Technical Details	AS PER SPECIFICATION
7. Estimated Delivery Period	EX STOCK
8. Estimated date reqd. at site	TWENTY WEEKS
9. Enclosures : Samples/Cat/Test Results	CATALOGUES

Meets/does not Meet Requirements

REMARKS

For WATSON KHONJI, CONSULTING ENGINEERS.

Date : 25/3/92.

Approved/Rejected

